

C. Subscriber must rectify all defects identified during the Final Inspection in a manner acceptable to Engineer prior to Sanitary Sewer Facilities being conveyed to HSE.

SECTION 1 – MANHOLES, PIPES AND FITTINGS

PART 1 – PRODUCTS

1.01 General Requirements

- A. Under general laying conditions, sewer pipe can be any one of the pipe materials specified in these Specifications provided, the material is that pipe type and standard indicated on the Construction Plans.
- B. Markings
 1. All pipe and fittings must be clearly marked in accordance with the various standards under which they are manufactured. All pipe must be marked with durable printing according to ASTM/AWWA standards.
 2. A marking must be provided on the spigot of each pipe utilizing bell joints to indicate when the pipe is driven home.

1.02 Polyvinyl Chloride ("PVC") Pipe

- A. PVC pipe and fittings must be smooth wall inside and out and must conform to ASTM D3034 and ASTM F1336 (SDR 26 or SDR 21), Type PSM or CAN/CSA-B182.2.M90, the more stringent must apply for sizes up to 15 inches; ASTM F679 (T-1; T-2 as approved by Engineer) or AASHTO M278 or CAN/CSA-B182.2.M90, the more stringent must apply for sizes greater than 15 inches; ASTM D2241 (SDR 21) for sizes up to 24 inches; ANSI/AWWA C900 (DR 18) for sizes 4 – 12 inches; ANSI/AWWA C905 (DR25 or DR 18) for sizes 14 – 24 inches.

- B. Minimum cell classification of pipe 15 inches or less in size must be 12454-B, 12454-C, 13364-C, or 12364-C as defined by ASTM D1784. Minimum cell classification of pipe greater than 15 inches in size must be 12454-C, 13364-B, or 12364-C as defined by ASTM D1784. All pipe must have a minimum tensile strength of 34.50 MPa as defined by ASTM D1784.

- C. Joints, on PVC sewer pipe, must be the integral bell type gasketed joint designed so when assembled, the elastomeric gasket inside the bell is compressed radially on the pipe spigot to form a positive seal. The joint must be designed to avoid displacement of the gasket when installed in accordance with manufacturer's recommendations. The joint must comply with ASTM F477 and ASTM F913 and the physical requirements of ASTM D3212 and Uni-Bell PVC Pipe Association's UNI-B-1 "Recommended Specifications for Thermoplastic Pipe Joints, Pressure and Non-Pressure Applications", the more stringent must apply. The gasket must be the only element depended upon to make the joint flexible and watertight.
- D. PVC pipe type ASTM D3034 (SDR 26) can be used to thirty (30) feet.

1.03 Fittings

- A. Fittings such as wyes, tees, and bends must be made in a manner that will provide strength and water tightness at least equal to the class of the adjacent mainline pipe to which they are joined. Fittings must conform to all other requirements specified for pipe of the corresponding class and diameter. Joints must be of the same type as used on the adjoining pipe. All fittings must be bell by bell. Bell by spigot fittings will not be permitted except at Engineer's discretion.
- B. Fabricated fittings (not molded as a single integral unit) and saddles will not be allowed. Plastic Trends, Inc. fittings are recognized as an acceptable alternate to this standard.
- C. If necessary, due to material shortage, water grade fittings may be substituted provided the application is clearly marked as sanitary sewer.

1.04 Manholes and Other Structures

- A. Manholes must be constructed of monolithic concrete or pre-cast manhole sections. Pre-cast manhole sections must conform to the requirements of ASTM C478 and manhole joints to the requirements of ASTM C443, except that the joint design of the pre-cast sections must consist of an overlapping joint joining section.
- B. Materials for Manholes and miscellaneous concrete structures must comply with the following:
 1. Concrete for pre-cast manhole sections and monolithic manholes must use four thousand (4000) psi concrete. Ready-mix concrete must conform to ASTM C94, alternate 2. Maximum size aggregate must be one and a half (1.5) inches. Slump must be between two (2) and four (4) inches with Penetron concrete admix by Penetron USA.
 2. Reinforcing steel must conform to ASTM A615, Grade 40 deformed bars or ASTM A616, Grade 40 deformed bars.
 3. Mortar materials:
 - a. Sand – ASTM C144, passing a #8 sieve.
 - b. Cement – ASTM C150, Type 1.
 - c. Water – must be potable.
 4. Joints on pre-cast manhole sections must utilize rubber gaskets meeting the requirements of ASTM C443 and these Specifications, the more stringent will apply. O-ring gaskets must be confined in a groove in the spigot end of the pre-cast manhole section. Profile gaskets must bear on a lateral face of the tongue to provide positive positioning. The joint must be further sealed as noted on HSE's Gravity Sanitary Sewer Details sheet.
 5. Manufacturer of pre-cast manholes must provide factory cut openings to produce a smooth, uniform, cylindrical hole of the proper size to accommodate the resilient connector. Resilient connectors can alternately be pre-cast-in-place by the manufacturer. All pipes entering and leaving manholes must have a resilient connector meeting the requirements of ASTM C923 firmly clamped around the pipe. The resilient connectors must be PSX gasket or Press Wedge II as manufactured by Press-Seal Gasket Corp. or similar flexible manhole sleeves as manufactured by Kor-N-Seal or equal.
 6. Without prior written consent of Engineer, pre-cast manhole sections must be steam cured and cannot be shipped from point of manufacture for at least five (5) days after having been cast. Upon written consent of Engineer, pre-cast manhole sections can be

shipped prior to five (5) days if they were manufactured of high-early strength concrete and are verified through testing to have achieved a strength acceptable to Engineer.

- 7. Manhole sections are to have a waterproof exterior coating applied prior to installation as approved by Engineer.
- 8. Manhole castings must be of good quality cast iron conforming to ASTM A48 or D1 conforming to ASTM A536, Grade 65-45-12 with concealed rectangular pick-hole. Refer to HSE's Gravity Sanitary Sewer Details sheet for detailed information. Unless specifically designated otherwise, manhole castings must be the non-locking type.
- 9. Manhole steps must be made from a steel reinforcing rod encapsulated in a copolymer polypropylene resin. The manhole steps must equal or exceed IOSHA requirements. Manhole steps manufactured by M.A. Industries, Inc., American Step Company, Inc., or equal are acceptable.
- 10. Any special manhole or miscellaneous concrete structures must be constructed as detailed on the Construction Plans.
- 11. Manhole bases must be combination pre-cast concrete base and first section as a single unit. Detailed drawings must be submitted to Engineer prior to casting or manufacture.
- 12. No interior surface applied materials can be used.
- 13. Concrete manhole joints are to be sealed by WrapIDSeal.
- 14. Riser rings are to be sealed by use of Kent Seal and exterior wrapped with WrapIDSeal or combination of butyl and shrink-wrap.
- 15. Fiber mesh reinforcement for Type 2 cleanouts: Application per cubic yard must equal a minimum of one and a half (1 ½) pounds. Fibers are for the control of cracking due to dry shrinkage and thermal expansion/contraction, to lower concrete permeability and to increase impact capacity, shatter resistance and abrasion resistance. Fiber mesh reinforcement must be manufactured by Fibermesh, 4019 Industry Drive, Chattanooga, TN 37416, or equal as approved by Engineer on a case-by-case basis.

PART 2 – EXECUTION

2.01 Handling and Cutting Pipe

- A. Each product to be incorporated into the Project must be handled into its position, placed, and supported only in such manner and by such means as Engineer accepts as satisfactory.
- B. Pipe and fittings must be handled carefully to avoid cracking or abrasion of the coating. Handle in a manner to ensure installation in sound and undamaged condition. Do not drop or bump. Use slings, lifting lugs, hooks, and other devices designed to protect pipe, joint elements, and coatings. Ship, move, and store with provisions to prevent movement or shock contact with adjacent units. Handle with equipment capable of performing the work with an adequate factor of safety against overturning or other unsafe procedures.
- C. Any fitting showing a crack and any fitting or pipe which received a severe blow which could have caused an incipient fracture, even though no such fracture can be seen, must be marked as rejected and removed at once from the site.
- D. In any pipe showing a distinct crack and in which it is believed there is no incipient fracture beyond the limits of the visible crack, the cracked portion, if so approved, may be cut off by Contractor before the pipe is laid so that the pipe used is perfectly sound. The cut must be made in the barrel at a point at least twelve (12) inches from the visible limits of the crack.
- E. All field cutting of pipe must be done in a neat, trim manner. Field cut pipe will only be allowed at manholes, tees, wyes, and at the connection of a new sanitary sewer to an existing sanitary sewer. The cut end must be beveled using a file or a wheel to produce a smooth level of approximately fifteen (15) degrees and a minimum depth of 1/3 of the pipe wall thickness.

2.02 Construction Staking

Contractor shall contact with a Land Surveyor, registered in the State of Indiana, to furnish and set all line and grade stakes (HUB) Land Surveyor will be required to set, or oversee the setting, all benchmark stakes necessary for the installation of any sanitary sewer facility being constructed. Temporary construction benchmarks shall be set in strategic locations, but no more than one thousand (1,000) feet from the Project, to facilitate the installation of grade stakes. Horizontal and vertical control will be required to be provided with the Record Drawings to be submitted to HSE upon completion of the Project. A permanent Benchmark shall be installed by Contactor at the entrance of a new development.

2.03 Laying Pipe

- A. Unless approved by Engineer, Contractor must not install different sizes, types, classifications, and grades of pipe between Manholes. No construction work will be permitted after 8:00 PM or dusk, whichever is earlier.
- B. All rough grading (on-site and off-site) must be finished to within one (1) foot of final grade prior to the start of construction of the Sanitary Sewer Facilities. Contractor must provide and protect survey grade stakes that enable Engineer to verify compliance with the rough grading requirement at least 5-days prior to a scheduled preconstruction meeting for sanitary sewer related work.
- D. Contractor must install all off-site laterals with a minimum cover of six (6) feet from top of pipe to grade. Laterals will be considered off-site if they are constructed in an area that will not be platted immediately upon completion.
- E. The point of commencement for laying pipe is to be the lowest point in the proposed line. Provisions for beginning construction at other than the lowest point in the proposed line shall require approval by Engineer. All bell and spigot pipe shall be laid with bell end pointing up grade.
- F. The existing sewer segment downstream from any connection must be cleaned by a vactor truck immediately after the connection to the existing sewer and plugging of the connection is finished.

If, for any reason, live or in-service Sanitary Sewer Facilities must be plugged, the accumulated wastewater must be pumped out at the location of the plug and either conveyed to an available manhole with sufficient capacity or transported to a proper disposal site. Additionally, the upstream lines and manholes must be cleaned and flushed to the location of the plug on completion of the work.

- H. All pipe must be bedded as described in these Specifications under Pipe Bedding and Haunching and on HSE's Gravity Sanitary Sewer Details sheet. Bell recesses must be excavated in advance of pipe laying so the entire pipe barrel will bear uniformly on the prepared sub-grade.
- I. The supporting of pipe on block will be permitted only where the pipe is to receive total concrete encasement. Encased pipe must be accurately and effectively supported and secured on crossing "X" rebar.
- J. All pipe must be laid accurately to the required line and grade in the manner prescribed by the pipe manufacturer and appropriate ASTM/AWWA standards. Each section of pipe must be laid to form a close, concentric joint with the adjoining pipe at an elevation conforming to the required grade. PVC gravity sewer pipe and fittings must, at a minimum, be installed in accordance with the directions contained in ASTM D2321.
- K. Obtain approval of Engineer of method proposed for transfer of line and grade from control of work.
- L. At a minimum, Contractor must use laser beam equipment to maintain accurate line and grade. Before proceeding to the next joint, the last joint must be checked for proper line and grade. Survey instruments bearing proof of calibration within prior six (6) months and capable of third order accuracy must be used for checking alignment and grade throughout the Project. It is the Contractor's responsibility to regularly test all equipment to assure compliance with manufacturer's specifications.
- M. Clean interior of all pipe and fittings prior to installation.
- N. When bell and spigot pipe is laid, the bell of the pipe must be cleaned of mud, sand, and other obstructions before the clean spigot of the next pipe is inserted. The joint must be made in a satisfactory manner in accordance with the recommendations of the manufacturer and the direction of Engineer. The new pipe must be shoved "home" firmly against the back of the bell and securely held until the joint has sealed. Experienced personnel must perform all joint work.
- O. Locate pipe joint to provide for differential movement at changes in type of pipe embedment or at changes in trench bottom material. Do not locate joint within eight (8) feet of Manhole walls, use full length pipe from up-stream connection. Clean and lubricate all joint and gasket surfaces with lubricant recommended by manufacturer. Check joint deflection for specified limits. No water in an excavation shall be permitted to enter the pipe. Contractor to have water under control prior to installing pipe and protect pipe interior from groundwater.
- Q. Perform pipe installation only when weather and trench conditions are suitable. Allow pipe to reach trench air temperature prior to installation. Contractor must discontinue pipe installation when there is a danger of the quality of work being impaired because of cold weather. Contractor is responsible for heating the pipe and jointing material to prevent freezing of joints. Pipe must not be laid on frozen ground. Pipe must not be installed unless the outside temperature is greater than thirty-two (32) degrees Fahrenheit.
- R. Install a temporary watertight plug at the end of the sewer when installed pipe is left unattended. Contractor must prevent all water, earth, or other material from entering Sanitary Sewer Facilities. An airtight, watertight plug must always be maintained in the Project at the point of connection with the existing sewer from the initiation of construction to the Completion of the Project. At least once a day, Contractor must inspect the plug for water tightness and pump out all accumulated water in excess of six (6) inches from the invert of the outgoing pipe. In the event any water, earth, or other material enters the downstream sewer, Contractor is responsible to HSE for the costs of sewage treatment, electrical power, equipment repairs, incidental damages, cleaning and any other costs or expenses related to such entry. Contractor shall pay HSE damages per occurrence.

- S. Pipe must be installed to cross storm sewers and other utilities at approximately ninety (90) degrees and must maintain a minimum horizontal separation (measured from outer spring line of each pipe) of ten (10) feet from all storm and utility structures.
- 2.04 Bores
 - A. Casing wall thickness as per Section 716 – Jacked Pipe of the "Indiana Department of Transportation Standard Specifications" latest edition.
 - B. All work within rights-of-way must be in accordance with the requirements of the governmental agency having jurisdiction. Where no procedures for a particular portion of the work are given, the recommendations of the "Indiana Department of Transportation Standard Specifications," latest edition, must be followed.
 - C. The gravity-flow carrier pipe shall be shimmed to proper line, elevation, and grade then and void between the two pipes shall be grouted with cellular grout following grade confirmation and testing.
 - D. Engineer recommends preliminary low-pressure air and mandrel testing of the carrier pipe prior to grouting.
 - E. Upon completion of the bore, Contractor must coordinate with Engineer to verify that the carrier pipe is on line and grade. Contractor must submit invert elevations to Engineer. For further information refer to HSE's Gravity Sanitary Sewer Detail sheet.
 - G. Contractor may request alternate methods or materials such as the use of directional boring and/or PE pipe. In this case, Engineer must approve in writing, the use of alternate methods or materials and Contractor performing the bore.

- 2.06 Concrete, Concrete Caps, and Concrete Cradles.
 - A. The strength of concrete indicated on all drawings, details, and specifications is twenty-eight (28) day compressive strength. Concrete caps, cradles, and encasement must be provided at all locations indicated on the Construction Plans. When so ordered by Engineer, concrete caps, cradles, and encasement not shown on the Construction Plans must be installed. When storm sewers cross Sanitary Sewer Facilities with less than eighteen (18) inches of vertical separation (from the outer edge of each pipe), the Sanitary Sewer Facilities must be supported with a concrete cradle. At Engineer's discretion, Contractor must take four (4) cylinders per five (5) cubic yards of concrete and provide certified test results to Engineer.
 - D. If the outside temperature is between twenty (20) and thirty-two (32) degrees Fahrenheit and rising, Contractor must use a fifty (50) percent ethylene-glycol/water mixture. If the outside temperature is forecasted to be below thirty-two (32) degrees Fahrenheit during the curing of any concrete or grout application, the concrete must be protected from freezing with insulation blankets acceptable to Engineer. All concrete work must be performed at an outside temperature of over twenty (20) degrees Fahrenheit and rising.

- 2.07 Manholes and Other Structures
 - A. All manhole structures to be coated on exterior with Tnemec Hi-Build Tnemec-Tar Series 46H-413 Polyamide Epoxy-Coal Tar for corrosion resistance. Recommended dry film thickness shall be no less than 16 to 20 mils. for all structures.
 - B. All manholes, flow monitoring/metering manholes and cleanouts must be constructed in accordance with HSE's Gravity Sanitary Sewer Details sheet.
 - C. In manholes with multiple inlets, Contractor must install all pipe from lowest to highest elevation. The lower elevation pipe must be extended to the next upstream manhole before commencing installation on the next higher sewer.
 - D. Unless otherwise approved by Engineer in writing, all flow monitoring/metering manholes must be at least five (5) feet in diameter.
 - E. Manhole channels must be formed and poured with concrete to the crown of the connecting pipe. The finished invert must be a semi-circular shaped, smooth channel directing flow to the downstream sewer. Changes in direction in base channels must be accomplished by smooth, constant radius turns in the channel joining the downstream channel tangentially. Concrete must be RE-CRETE twenty (20) minute set or approved equal and must use Dayton Superior's J-40 or R-40 or approved equal liquid bonding agent. Patches over one (1) thick must be cleaned to fresh concrete and filled with quickest high strength grout.

- 2.08 Bores
 - A. Where approved by Engineer, manholes can be added to an existing sanitary sewer. No "doghouse" or "saddle" structures will be permitted. The upstream and downstream sanitary sewers between the new manhole and the existing manholes must be low-pressure air tested and deflection tested. The new manhole must also be vacuum tested while maintaining continuous service.
 - B. Manholes must be placed and aligned to provide vertical sides within a tolerance not exceeding one (1) inch up to ten (10) feet in depth and two (2) inches up to twenty (20) feet in depth, plus one-eighth (1/8) inch per foot over twenty (20) feet in depth. Tolerance to be checked with a plumb line.
 - H. All cored holes, penetrations, and/or other openings into a manhole or other sanitary structure must have a minimum separation of six (6) to eight (8) inches from any joint, as measured from the nearest joint shoulder (interior or exterior) to the penetration.

- 2.10 Right-of-Way Guidelines/Restrictions
 - A. All sanitary sewer related activity planned to transgress or potentially be located within the rights-of-way of any public governing body or utility located in same shall be reviewed by any and all utilities for potential concerns or conflicts in addition to an Asset Protection specialist to obtain prior written approval.

- 2.11 Excavating
 - A. De-watering
 - 1. Contractor must provide, install, and operate sufficient trenches, sumps, pumps, hoses, piping, well points, etc. to depress and maintain the groundwater level below the base of the excavation until all Sanitary Sewer Facilities are Completed. Provide sufficient dikes and de-watering equipment and make satisfactory arrangements for the disposal of the water without undue interference with other work, damage to property, or damage to the environment.

- B. Finished grade around manholes and castings must be set at an elevation to prevent surface water runoff from running over or ponding on top of the manhole.
- K. Manhole frames must be securely anchored to the cone or adjusting ring with bolts and concrete anchors adequate in length to penetrate the structure.
- L. Flat top structures are generally not permitted. If a flat top structure is permitted, Contractor must receive written approval from Engineer. No more than eight (8) inches of adjusting rings can be installed on flat top structures.
- M. Engineer has the right to cut cores from such pieces of concrete manholes as he desires for such inspection and tests as he may wish to apply. Holes left by the removal of cores must be filled in an acceptable manner to form a watertight and structurally sound repair.
- N. Engineer may, for inspection or testing purposes, take samples of concrete after it has been mixed or as it is being placed in the forms or molds.
- O. All grout used to seal or join structures must be non-shrink grout.

- 2.08 Laterals, Stubs, Connections, Bulkheads, and Miscellaneous Items
 - A. Where existing sewers carrying sanitary sewage are encountered, Contractor must provide and maintain temporary or redundant pumping systems to prevent a nuisance.
 - B. Where called for on the Construction Plans, lateral connections and stubs for future sewer connections must be provided. Lateral locations must be recorded on a HSE digital Lateral Locate Form. The upstream end of lateral connections and mainline stubs must be field marked with a two by four (2" X 4"), wrapped with #10 tracer wire. The depth of the lateral must be indicated on the marker.
 - C. Without written permission from Engineer, Contractor cannot connect any existing sewers or house service into the Project prior to the Project being deemed Complete by HSE.
 - D. Laterals must be installed to cross storm sewers and other utilities at approximately ninety (90) degrees and must maintain a minimum horizontal separation of ten (10) feet from exterior surface of all water lines, storm structures and utilities. Contractor must notify Engineer least seventy-two (72) hours prior to any construction of storm sewers that may affect previously constructed Sanitary Sewer Facilities. All laterals must be installed with an insulated #10 tracer wire along the top of pipe from the way to the terminus. The mainline Contractor shall install the wire from the way to the lateral marker at the surface. The lateral Contractor shall extend the wire from the terminus to the cleanout adjacent to the building.
 - G. All lateral tracer wire connections shall be soldered and DryConn Direct Buried Lug electrical insulation, corrosion resistant, wire splice kit to be used at ALL spliced locations.

- 2.09 Existing Utilities, Structures, Property, Etc.
 - A. Prior to proceeding, all improvements, including but not limited to, poles, trees, fences, sewer, gas, water or other pipes, wires, conduits, manholes, railroad tracks, buildings, structures, property, etc. along the route of Sanitary Sewer Facilities must not be disturbed without the approval of the responsible representative. Following authorization by the associated owner's representative, the contractor is to support and protect from damage all potentially affected property.
 - B. Moveable item such as mailboxes can be temporarily relocated during construction, provided their function is maintained. Place moveable items back in their original location immediately after backfilling is finished, unless otherwise shown on the Construction Plans. Any moveable items damaged during construction must be replaced by an item of equal or better quality.
 - C. Contractor must proceed with caution in the excavation and preparation of trenches so the exact location of underground utilities and structures, both known and unknown, can be determined. Contractor is responsible for repair of utilities and structures when broken or otherwise damaged.
 - D. The width of the trench is predicated upon the diameter of the pipe and depth the pipe is to be installed. If the specified trench width is exceeded, Contractor is responsible for the provision and installation, at his own expense, of all remedial measures required by Engineer.
 - E. Where pipes or conduits cross the trench, Contractor must support said pipes and conduits without damage to them and without interrupting their service. The manner of supporting such pipes, etc. is subject to approval by owner of the pipe or conduit.
 - F. When utility lines must be removed or relocated for the Project, Contractor must notify Engineer and utility line owner in ample time for necessary measures to be taken to prevent interruption of the utility's service.
 - G. Contractor must conduct the work so that no equipment, material, or debris will be placed or allowed to fall upon private property in the vicinity of the Project, unless Contractor has first obtained the property owner's written consent and provided a copy to Engineer.
 - H. All excavated material must be piled in a manner that will avoid obstructing sidewalks, driveways, and thoroughfares. Hydrants under pressure, valve pit covers, valve boxes, curb stop boxes, fire and police call boxes, or other utility controls must be left unobstructed and accessible during the Project. Contractor must prevent runoff from stored piles of excavated material from entering ditches, waterways, gutters, or storm sewers.

- 2.10 Right-of-Way Guidelines/Restrictions
 - A. All sanitary sewer related activity planned to transgress or potentially be located within the rights-of-way of any public governing body or utility located in same shall be reviewed by any and all utilities for potential concerns or conflicts in addition to an Asset Protection specialist to obtain prior written approval.

- 2.11 Excavating
 - A. De-watering
 - 1. Contractor must provide, install, and operate sufficient trenches, sumps, pumps, hoses, piping, well points, etc. to depress and maintain the groundwater level below the base of the excavation until all Sanitary Sewer Facilities are Completed. Provide sufficient dikes and de-watering equipment and make satisfactory arrangements for the disposal of the water without undue interference with other work, damage to property, or damage to the environment.

- 2.12 Restoration
 - A. This section pertains to the restoration of the Project site upon Completion of the work.
 - B. Restoration of improvements on public and private property must be in-kind and acceptable to the owner.
 - C. Restoration of road surfaces, drainage ways and other similar improvements within the public right-of-way or acquired easements must be in accordance with the directions of the government agency or public entity having jurisdiction.
 - D. All vegetated areas disturbed or damaged during construction must be re-vegetated with a stand of grass. Agricultural areas and areas currently under construction do not require re-vegetation.

- 1. Backfills, fills, and embankments must be brought to a sub-grade level six (6) inches below finished grade. When sub-grades have settled, deposit and spread fine raked topsoil, ready for seeding, to a finished depth of at least six (6) inches.
- 2. Commercial fertilizer, 6-12-12 or equal, must be uniformly spread at the rate of thirty-five (35) pounds per one thousand (1,000) square feet over the topsoil by a mechanical spreader at least forty-eight (48) hours before seeding and mixed into the soil for a depth of two (2) inches.
- 3. A grass seed mixture comprised of thirty-five (35) parts Kentucky Blue Grass, thirty (30) parts Perennial Ryegrass, thirty (30) parts Kentucky 31 Fescue and no more than five (5) parts inert matter must be sown on the disturbed areas at a rate of three (3) pounds per one thousand (1,000) square feet. Seeding must be done only between April 1 and June 1 or August 15 and October 15.
- 4. Seeded areas must be mulched with straw, hay, wood cellulose fiber, or cane fiber. Straw or hay must be applied at a rate of two and a half (2 ½) tons per acre. Wood cellulose or cane fiber mulch must be applied at a rate of one thousand (1,000) pounds per acre. On special areas of high-water concentration, unstable soils, or sloped surfaces, manufactured mulch materials such as soil retention blankets, erosion control netting or others may be required by Engineer. Manufactured mulch materials must be installed according to the manufacturer's recommendations.
- 5. The seeded areas must be thoroughly watered with a fine spray to prevent wash out of the seed. Areas shall be maintained and patched as directed by Engineer. A satisfactory stand of grass at least one (1) inch in height, without bare spots, will be required. Within three (3) months after Project Completion, Contractor must correct defective work, such as settled areas, uneven road surfaces, bare spots in grass coverage, erosion, and gullies.

- 6. All job excavated materials which are used for trench backfill above pipe embedment and which are to be compacted by any method except settlement by water, must be "clean backfill".
- 7. Material excavated from an open trench can be used for backfilling, from the pipe to six (6) inches below finished grade, providing it meets the requirements of "clean backfill" or providing a different type of backfill material has not been specified or shown on the Construction Plans. Where excavated material is used for backfilling and there is a deficiency due to the rejection of a part thereof, Contractor, upon direction of Engineer, must remove the rejected material from the site and furnish an additional quantity of "clean backfill" at his own expense.
- 8. Excavated material must be placed immediately after the hand backfill in such a manner to prevent the formation of voids and potential damage to pipe. The earth backfill must be compacted to ninety-five (95) percent Proctor density at a minimum or mounded six (6) inches for settlement.
- 9. In no case must backfill be dropped from such height or in such volume that its impact damages Sanitary Sewer Facilities. Engineer reserves the right to regulate and control the manner of depositing such backfill. Contractor will be held liable for damage to the Sanitary Sewer Facilities.
- 10. Settling of backfill by flooding or puddling will not be permitted.
- 11. Excess trench material must be roughly graded over the trench in a timely manner soon after the pipe is installed. This material must be mounded over the trench with a crown height of no more than six (6) inches, feathered to existing grade, until final settlement has occurred, and the trench is ready for grading and cleanup. An exception to this would be trenches in traveled pathways. Any excess must be hauled off and disposed of or stored by Contractor.

- 12. After settlement of backfill, and immediately before restoration of vegetated areas, grade and remove excess earth in unpaired areas. Remove to a depth of six (6) inches below finished grade. Place six (6) inches of topsoil over entire area to be restored.

- 13. Backfills, fills, and embankments must be brought to a sub-grade level six (6) inches below finished grade. When sub-grades have settled, deposit and spread fine raked topsoil, ready for seeding, to a finished depth of at least six (6) inches.
- 2. Commercial fertilizer, 6-12-12 or equal, must be uniformly spread at the rate of thirty-five (35) pounds per one thousand (1,000) square feet over the topsoil by a mechanical spreader at least forty-eight (48) hours before seeding and mixed into the soil for a depth of two (2) inches.
- 3. A grass seed mixture comprised of thirty-five (35) parts Kentucky Blue Grass, thirty (30) parts Perennial Ryegrass, thirty (30) parts Kentucky 31 Fescue and no more than five (5) parts inert matter must be sown on the disturbed areas at a rate of three (3) pounds per one thousand (1,000) square feet. Seeding must be done only between April 1 and June 1 or August 15 and October 15.
- 4. Seeded areas must be mulched with straw, hay, wood cellulose fiber, or cane fiber. Straw or hay must be applied at a rate of two and a half (2 ½) tons per acre. Wood cellulose or cane fiber mulch must be applied at a rate of one thousand (1,000) pounds per acre. On special areas of high-water concentration, unstable soils, or sloped surfaces, manufactured mulch materials such as soil retention blankets, erosion control netting or others may be required by Engineer. Manufactured mulch materials must be installed according to the manufacturer's recommendations.
- 5. The seeded areas must be thoroughly watered with a fine spray to prevent wash out of the seed. Areas shall be maintained and patched as directed by Engineer. A satisfactory stand of grass at least one (1) inch in height, without bare spots, will be required. Within three (3) months after Project Completion, Contractor must correct defective work, such as settled areas, uneven road surfaces, bare spots in grass coverage, erosion, and gullies.

- 13. Backfills, fills, and embankments must be brought to a sub-grade level six (6) inches below finished grade. When sub-grades have settled, deposit and spread fine raked topsoil, ready for seeding, to a finished depth of at least six (6) inches.
- 2. Commercial fertilizer, 6-12-12 or equal, must be uniformly spread at the rate of thirty-five (35) pounds per one thousand (1,000) square feet over the topsoil by a mechanical spreader at least forty-eight (48) hours before seeding and mixed into the soil for a depth of two (2) inches.
- 3. A grass seed mixture comprised of thirty-five (35) parts Kentucky Blue Grass, thirty (30) parts Perennial Ryegrass, thirty (30) parts Kentucky 31 Fescue and no more than five (5) parts inert matter must be sown on the disturbed areas at a rate of three (3) pounds per one thousand (1,000) square feet. Seeding must be done only between April 1 and June 1 or August 15 and October 15.
- 4. Seeded areas must be mulched with straw, hay, wood cellulose fiber, or cane fiber. Straw or hay must be applied at a rate of two and a half (2 ½) tons per acre. Wood cellulose or cane fiber mulch must be applied at a rate of one thousand (1,000) pounds per acre. On special areas of high-water concentration, unstable soils, or sloped surfaces, manufactured mulch materials such as soil retention blankets, erosion control netting or others may be required by Engineer. Manufactured mulch materials must be installed according to the manufacturer's recommendations.
- 5. The seeded areas must be thoroughly watered with a fine spray to prevent wash out of the seed. Areas shall be maintained and patched as directed by Engineer. A satisfactory stand of grass at least one (1) inch in height, without bare spots, will be required. Within three (3) months after Project Completion, Contractor must correct defective work, such as settled areas, uneven road surfaces, bare spots in grass coverage, erosion, and gullies.

- 13. Backfills, fills, and embankments must be brought to a sub-grade level six (6) inches below finished grade. When sub-grades have settled, deposit and spread fine raked topsoil, ready for seeding, to a finished depth of at least six (6) inches.
- 2. Commercial fertilizer, 6-12-12 or equal, must be uniformly spread at the rate of thirty-five (35) pounds per one thousand (1,000) square feet over the topsoil by a mechanical spreader at least forty-eight (48) hours before seeding and mixed into the soil for a depth of two (2) inches.
- 3. A grass seed mixture comprised of thirty-five (35) parts Kentucky Blue Grass, thirty (30) parts Perennial Ryegrass, thirty (30) parts Kentucky 31 Fescue and no more than five (5) parts inert matter must be sown on the disturbed areas at a rate of three (3) pounds per one thousand (1,000) square feet. Seeding must be done only between April 1 and June 1 or August 15 and October 15.
- 4. Seeded areas must be mulched with straw, hay, wood cellulose fiber, or cane fiber. Straw or hay must be applied at a rate of two and a half (2 ½) tons per acre. Wood cellulose or cane fiber mulch must be applied at a rate of one thousand (1,000) pounds per acre. On special areas of high-water concentration, unstable soils, or sloped surfaces, manufactured mulch materials such as soil retention blankets, erosion control netting or others may be required by Engineer. Manufactured mulch materials must be installed according to the manufacturer's recommendations.
- 5. The seeded areas must be thoroughly watered with a fine spray to prevent wash out of the seed. Areas shall be maintained and patched as directed by Engineer. A satisfactory stand of grass at least one (1) inch in height, without bare spots, will be required. Within three (3) months after Project Completion, Contractor must correct defective work, such as settled areas, uneven road surfaces, bare spots in grass coverage, erosion, and gullies.

- 13. Backfills, fills, and embankments must be brought to a sub-grade level six (6) inches below finished grade. When sub-grades have settled, deposit and spread fine raked topsoil, ready for seeding, to a finished depth of at least six (6) inches.
- 2. Commercial fertilizer, 6-12-12 or equal, must be uniformly spread at the rate of thirty-five (35) pounds per one thousand (1,000) square feet over the topsoil by a mechanical spreader at least forty-eight (48) hours before seeding and mixed into the soil for a depth of two (2) inches.
- 3. A grass seed mixture comprised of thirty-five (35) parts Kentucky Blue Grass, thirty (30) parts Perennial Ryegrass, thirty (30) parts Kentucky 31 Fescue and no more than five (5) parts inert matter must be sown on the disturbed areas at a rate of three (3) pounds per one thousand (1,000) square feet. Seeding must be done only between April 1 and June 1 or August 15 and October 15.
- 4. Seeded areas must be mulched with straw, hay, wood cellulose fiber, or cane fiber. Straw or hay must be applied at a rate of two and a half (2 ½) tons per acre. Wood cellulose or cane fiber mulch must be applied at a rate of one thousand (1,000) pounds per acre. On special areas of high-water concentration, unstable soils, or sloped surfaces, manufactured mulch materials such as soil retention blankets, erosion control netting or others may be required by Engineer. Manufactured mulch materials must be installed according to the manufacturer's recommendations.
- 5. The seeded areas must be thoroughly watered with a fine spray to prevent wash out of the seed. Areas shall be maintained and patched as directed by Engineer. A satisfactory stand of grass at least one (1) inch in height, without bare spots, will be required. Within three (3) months after Project Completion, Contractor must correct defective work, such as settled areas, uneven road surfaces, bare spots in grass coverage, erosion, and gullies.

- 13. Backfills, fills, and embankments must be brought to a sub-grade level six (6) inches below finished grade. When sub-grades have settled, deposit and spread fine raked topsoil, ready for seeding, to a finished depth of at least six (6) inches.
- 2. Commercial fertilizer, 6-12-12 or equal, must be uniformly spread at the rate of thirty-five (35) pounds per one thousand (1,000) square feet over the topsoil by a mechanical spreader at least forty-eight (48) hours before seeding and mixed into the soil for a depth of two (2) inches.
- 3. A grass seed mixture comprised of thirty-five (35) parts Kentucky Blue Grass, thirty (30) parts Perennial Ryegrass, thirty (30) parts Kentucky 31 Fescue and no more than five (5) parts inert matter must be sown on the disturbed areas at a rate of three (3) pounds per one thousand (1,000) square feet. Seeding must be done only between April 1 and June 1 or August 15 and October 15.
- 4. Seeded areas must be mulched with straw, hay, wood cellulose fiber, or cane fiber. Straw or hay must be applied at a rate of two and a half (2 ½) tons per acre. Wood cellulose or cane fiber mulch must be applied at a rate of one thousand (1,000) pounds per acre. On special areas of high-water concentration, unstable soils, or sloped surfaces, manufactured mulch materials such as soil retention blankets, erosion control netting or others may be required by Engineer. Manufactured mulch materials must be installed according to the manufacturer's recommendations.
- 5. The seeded areas must be thoroughly watered with a fine spray to prevent wash out of the seed. Areas shall be maintained and patched as directed by Engineer. A satisfactory stand of grass at least one (1) inch in height, without bare spots, will be required. Within three (3) months after Project Completion, Contractor must correct defective work, such as settled areas, uneven road surfaces, bare spots in grass coverage, erosion, and gullies.